Property Condition Report

Case Number:	011-982090	**Contract Area:**	6A
Current Step:	1c-Ready to Show Condition	**Address:**	1389 FULTON AVE
Step Date:	02/09/2026	**City, St Zip:**	TARRANT, AL 35217-0000
HOC:	Atlanta		

Property Condition Report

Item Description/Condition		Item Functionality		Functionality/Test Notes
Cooling/Air-Conditioner:	**N/A**	**HVAC tested and functional?:**	No	System Incomplete Missing Components
--Heating/Furnace:	**N/A**			
--HVAC System Duct:	**N/A**			
Electrical Wiring:	**OK**	**Electric supply tested and functional?:**	No	Not testeddue to outdated electrical (knob & tube)
--Other:	**N/A**			
--Other:	**N/A**			
Stove/Range/Oven:	**N/A**	**Built-in appliances tested and functional?:**	No	Appliances missing could not test
--Kitchen Cabinets:	**OK**			
--Other:	**N/A**			
Plumbing:	**OK**	**Water supply tested and functional?:**	Yes	Pressure Test PASS
--Sink:	**OK**			
--Other:	**N/A**			
Water Heater:	**OK**	**Water heater functional?:**	Yes	Water heater visually inspected PASS
Sewer/Septic System:	**N/A**	**Sanitary & plumbing system functional?:**	Yes	Pour water/antifreeze in drains PASS
--Toilet:	**OK**			
--Other:	**N/A**			
Roof:	**OK**	**Roofing in acceptable condition?:**	Yes	PASS - visually inspected peaks, valleys, ridge lines/caps, chimneys soffits, vents
--Other:	**N/A**			