Property Condition Report

Case Number:	013-065088	**Contract Area:**	6A
Current Step:	1c-Ready to Show Condition	**Address:**	7754 MARKET ST
Step Date:	10/13/2026	**City, St Zip:**	OAKMAN, AL 35579-0000
HOC:	Atlanta		

Property Condition Report

Item Description/Condition		Item Functionality		Functionality/Test Notes
Cooling/Air-Conditioner:	**OK**	**HVAC tested and functional?:**	Yes	GENERATOR
--Heating/Furnace:	**OK**			
--HVAC System Duct:	**OK**			
Electrical Wiring:	**OK**	**Electric supply tested and functional?:**	Yes	GENERATOR
--Other:	**OK**			
--Other:	**OK**			
Stove/Range/Oven:	**OK**	**Built-in appliances tested and functional?:**	Yes	GENERATOR
--Kitchen Cabinets:	**OK**			
--Other:	**OK**			
Plumbing:	**OK**	**Water supply tested and functional?:**	Yes	PRESSURE TEST PASS
--Sink:	**OK**			
--Other:	**OK**			
Water Heater:	**OK**	**Water heater functional?:**	Yes	DRAINED
Sewer/Septic System:	**OK**	**Sanitary & plumbing system functional?:**	Yes	POURED ANTIFREEZE DOWN DRAINS
--Toilet:	**OK**			
--Other:	**OK**			
Roof:	**OK**	**Roofing in acceptable condition?:**	Yes	VISUAL
--Other:	**OK**			