Property Condition Report

Case Number:	023-472505	**Contract Area:**	3S
Current Step:	1c-Ready to Show Condition	**Address:**	45985 N HIGHWAY 288
Step Date:	07/22/2026	**City, St Zip:**	YOUNG, AZ 85554-0000
HOC:	Santa Ana		

Property Condition Report

Item Description/Condition		Item Functionality		Functionality/Test Notes
Cooling/Air-Conditioner:	**N/A**	**HVAC tested and functional?:**	N/A	Generator/220 Plug/Breaker Panel
--Heating/Furnace:	**N/A**			
--HVAC System Duct:	**N/A**			
Electrical Wiring:	**Damaged**	**Electric supply tested and functional?:**	No	Generator/220 Plug/Breaker Panel Kitchen outlet previously burned
--Other:	**N/A**			
--Other:	**N/A**			
Stove/Range/Oven:	**N/A**	**Built-in appliances tested and functional?:**	No	Generator/220 Plug/Breaker Panel
--Kitchen Cabinets:	**OK**			
--Other:	**OK**			
Plumbing:	**Damaged**	**Water supply tested and functional?:**	No	Pressure test; Fail Unknown issue, would not build pressure
--Sink:	**N/A**			
--Other:	**N/A**			
Water Heater:	**OK**	**Water heater functional?:**	Yes	Inspected HWH components; pass with no deficiencies found
Sewer/Septic System:	**OK**	**Sanitary & plumbing system functional?:**	Yes	Pour Water/Antifreeze in Drains; Pass
--Toilet:	**OK**			
--Other:	**OK**			
Roof:	**Damaged**	**Roofing in acceptable condition?:**	No	Roof failed inspection. Damage in rear
--Other:	**OK**			