Property Condition Report

Case Number:	053-152416	**Contract Area:**	1D
Current Step:	6-Listed for Sale	**Address:**	1625 VERBENA ST
Step Date:	10/14/2026	**City, St Zip:**	DENVER, CO 80220-0000
HOC:	Denver		

Property Condition Report

Item Description/Condition		Item Functionality		Functionality/Test Notes
Cooling/Air-Conditioner:	**OK**	**HVAC tested and functional?:**	Yes	Continuity is good.
--Heating/Furnace:	**OK**			
--HVAC System Duct:	**OK**			
Electrical Wiring:	**OK**	**Electric supply tested and functional?:**	Yes	Continuity is good.
--Other:	**N/A**			
--Other:	**N/A**			
Stove/Range/Oven:	**OK**	**Built-in appliances tested and functional?:**	Yes	Continuity is good.
--Kitchen Cabinets:	**OK**			
--Other:	**N/A**			
Plumbing:	**OK**	**Water supply tested and functional?:**	Yes	Pressure test pass
--Sink:	**OK**			
--Other:	**OK**			
Water Heater:	**OK**	**Water heater functional?:**	Yes	visual inspection pass
Sewer/Septic System:	**OK**	**Sanitary & plumbing system functional?:**	Yes	Pour anti freeze down drain pass
--Toilet:	**OK**			
--Other:	**N/A**			
Roof:	**OK**	**Roofing in acceptable condition?:**	Yes	visual inspection pass
--Other:	**OK**			