Property Condition Report

Case Number:	244-060748	**Contract Area:**	5P
Current Step:	2-Appraisal Complete	**Address:**	227 CANEY CT
Step Date:	08/13/2026	**City, St Zip:**	PRINCE FREDERICK, MD 20678-0000
HOC:	Philadelphia		

Property Condition Report

Item Description/Condition		Item Functionality		Functionality/Test Notes
Cooling/Air-Conditioner:	**OK**	**HVAC tested and functional?:**	Yes	System Tested Functional at time of inspection
--Heating/Furnace:	**OK**			
--HVAC System Duct:	**OK**			
Electrical Wiring:	**OK**	**Electric supply tested and functional?:**	Yes	System Tested Functional at time of inspection
--Other:	**OK**			
--Other:	**OK**			
Stove/Range/Oven:	**Missing**	**Built-in appliances tested and functional?:**	No	System Tested Functional at time of inspection
--Kitchen Cabinets:	**OK**			
--Other:	**OK**			
Plumbing:	**OK**	**Water supply tested and functional?:**	Yes	System Tested Functional at time of inspection
--Sink:	**OK**			
--Other:	**OK**			
Water Heater:	**OK**	**Water heater functional?:**	Yes	System Tested Functional at time of inspection
Sewer/Septic System:	**OK**	**Sanitary & plumbing system functional?:**	Yes	System Tested Functional at time of inspection
--Toilet:	**OK**			
--Other:	**OK**			
Roof:	**OK**	**Roofing in acceptable condition?:**	Yes	System Tested Functional at time of inspection
--Other:	**OK**			