Property Condition Report

Case Number:	544-374341	**Contract Area:**	5P
Current Step:	2-Appraisal Complete	**Address:**	308 FAWN DR
Step Date:	09/01/2026	**City, St Zip:**	WINCHESTER, VA 22602-0000
HOC:	Philadelphia		

Property Condition Report

Item Description/Condition		Item Functionality		Functionality/Test Notes
Cooling/Air-Conditioner:	**OK**	**HVAC tested and functional?:**	Yes	generator testing
--Heating/Furnace:	**OK**			
--HVAC System Duct:	**OK**			
Electrical Wiring:	**OK**	**Electric supply tested and functional?:**	Yes	generator testing
--Other:	**OK**			
--Other:	**OK**			
Stove/Range/Oven:	**OK**	**Built-in appliances tested and functional?:**	Yes	generator testing
--Kitchen Cabinets:	**OK**			
--Other:	**OK**			
Plumbing:	**Damaged**	**Water supply tested and functional?:**	No	pressure test failed
--Sink:	**OK**			
--Other:	**OK**			
Water Heater:	**OK**	**Water heater functional?:**	Yes	visual inspection
Sewer/Septic System:	**OK**	**Sanitary & plumbing system functional?:**	Yes	pouring antifreeze into drains
--Toilet:	**OK**			
--Other:	**OK**			
Roof:	**OK**	**Roofing in acceptable condition?:**	Yes	visual inspection
--Other:	**OK**			